

TIER 3 PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for VOYAGER AT WHITE MOUNTAIN LAKES WC

Our water system violated drinking water standards over the past few years. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the past few years we have missed monitoring for multiple contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year; how often we are supposed to sample and how many samples we are supposed to take; how many samples we took; when samples should have been taken; and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
Lead and Copper	2020 – Annual 2021/2022 – 6 months	0	2020, July-December 2021. January- June 2022.	Samples will be taken this year, 2023.
Total Coliform	2 per month	0	February 2019. June, July 2021. February 2022. February, March, April 2023.	May 2023
Total Coliform Triggered Groundwater	1 per positive total coliform	0	October 2022	A groundwater sample will be taken this year, 2023.

What is being done?

The water system has hired a new operator and samples will be taken and submitted on time moving forward.

For more information, please contact Blake Anderson at 928-940-0042 or Blake@Mogollonwater.com

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by VOYAGER AT WHITE MOUNTAIN LAKES WATER COMPANY
State Water System ID#: AZ0409034

Date distributed:

CCR, Tier 3 Public Notification
Revised 01-20-10